



Vineland

FIRE PREVENTION BUREAU

Brian Murray
Fire Official
(856) 794 – 4000 x 4747

640 E. Wood Street – P.O. Box 1508 – Vineland, New Jersey 08362-1508

NJ UNIFORM FIRE CODE: COOKING VENDOR GUIDELINES

- The following are minimum guidelines for each cooking vendor at festivals, carnivals, etc.
- A site plan may be required by the Fire Official prior to event.

N.J.A.C. 5:70-2.7(a); All cooking vendors shall be required to apply for a fire safety permit issued by the NJ Division of Fire Safety. All permits shall be made available to the fire official upon inspection.

N.J.A.C. 5:70-2.7(f); The fire official upon inspection may deny or revoke a permit at any time; this can be due to failure to meet the permit conditions, unabated fire code violations or unsafe conditions.

Permits will not be issued unless payment is made in full. Check, cash or money order.

FIRE EXTINGUISHER: All cooking vendors shall supply their own fire extinguishers.

N.J.A.C. 5:70-3, 906.2; All fire extinguishers shall comply with NFPA 10/2002. All fire extinguishers shall have a valid dated inspection tag, good of one year.

N.J.A.C. 5:70-3, 904.12.5; Class K portable fire extinguishers are required for cooking with vegetable or animal oils and fats.

N.J.A.C. 5:70-3, 904.12.5.1; Class K portable fire extinguishers are required for cooking with solid fuel.

N.J.A.C. 5:70-3, 904.12.5.2; Class K portable fire extinguishers required for deep fat fryers. (See 2006 IFC-NJ for size and quantity)

PROPANE TANK:

N.J.A.C. 5:70-3, 3003.5.3; Propane tanks shall be secured, to prevent falling over.

N.J.A.C. 5:70-3, 6103.1; Propane tanks and equipment shall comply with NFPA 58/2004.

N.J.A.C. 5:70-3, 6104.3; Propane tanks shall not be taken into buildings/tents.

Mobile Canteens & Cooking Trailers:

N.J.A.C. 5:70-4.7(g) All cooking operations that produce grease laden vapors shall be equipped with a ventilating hood, duct, and automatic fire suppression system.

N.J.A.C. 5:70-3, 904.6; Dry chemical extinguishing systems shall be maintained and inspected semi-annually as per NFPA 17/2002.

N.J.A.C. 5:70-3, 904.5; Wet chemical extinguishing systems shall be maintained and inspected semi-annually as per NFPA 17A/2002.

N.J.A.C. 5:70-3, 609.2; Excessive grease and residue buildup on kitchen exhaust systems, cleaning required.

MISCELLANEOUS:

N.J.A.C. 5:70-3, 104.3; All appliances shall be listed and labeled and approved by the fire code official. (No home made appliances).

N.J.A.C. 5:70-3, 2403.8.2; No vehicles shall be parked within 5 feet of tents or canopies.

N.J.A.C. 5:70-3, 2404.15.3; Suitable barricades shall be provided to maintain a distance of 5 feet between the heat producing appliance and the public.

- Propane tanks between 4 and 40 lbs shall have an Overfill Protection Device for filling in NJ.
- Propane tanks shall be hydro tested every 12 years, and not dented or badly rusted.
- Regulator shall be in good condition and the relief valve shall face away from the public areas.
- All plastic type protective caps shall be removed from all propane tanks before operating.
- Hoses shall not be frayed or cracked, and there shall not be any type of tape on the hose.
- Hoses shall not be covered with grease and shall not be swollen.
- Hoses shall not create a tripping hazard
- Only approved lighter fluid shall be used for charcoal grills.
- Sterno warmers may be used provided the fuel containers are properly protected from being knocked over and if the fuel containers are properly enclosed within the warmer units.